

April 24th, 2018

TO ALL TENDERERS

LOWER SOUTH RIVER WELL NO. 7 BUILDING

We attach herewith a copy of Addendum No. 1 to the tender documents. Please take note of the contents and amend your copy of the documents accordingly.

General Contractors are responsible for ensuring that all sub contractors are provided with a copy of the addendum.

Please acknowledge receipt of this information accordingly on page 1 of the Tender Form.

Very truly yours
STRAIT ENGINEERING LIMITED



Kelsey DeCoste, EIT.

Attch.
Addendum No. 1 (1 Page)

Addendum No. 1
Municipality of the County of Antigonish
Well #7 Building – Lower South River
Project No. 18-01

April 24th, 2018

1. In Section “INSTRUCTION TO BIDDERS” found in the specifications:

Sub-Section 1.0 TENDER CALL, Paragraph Three is to change to the following,

“Each tender must be accompanied by a certified cheque in the amount of 10% of the bid amount or a Bid Bond in the amount of 10% of the bid amount and a Consent of Surety for the required fifty percent (50%) Performance Bond and fifty percent (50%) Labour and Materials Bond. In lieu of bonding the Municipality will accept a certified cheque in the amount of 10% of the bid amount as project securities.”

April 25, 2018

TO ALL TENDERERS


RE: LOWER SOUTH RIVER – WELL NO. 7 - BUILDING

We attach herewith a copy of Addendum No. 2 to the tender documents. Please take note of the contents and amend your copy of the documents accordingly.

General Contractors are responsible for ensuring that all sub-contractors are provided with a copy of the addendum.

Please acknowledge receipt of this information accordingly on page 1 of the Tender Form.

Very truly yours
STRAIT ENGINEERING LIMITED



R. Bruce Latimer, P. Eng.

attch:

**Addendum No. 2
Municipality of the County of Antigonish
Lower South River - Well No. 7 - Building
Project No. 18-01**

April 25, 2018

1. **Please be advised that the closing date of this tender will be extended to Thursday, May 10, 2018 up until 2:00pm local time.**

May 8, 2018

TO ALL TENDERERS

RE: LOWER SOUTH RIVER – WELL NO. 7 - BUILDING

We attach herewith a copy of Addendum No. 3 to the tender documents. Please take note of the contents and amend your copy of the documents accordingly.

General Contractors are responsible for ensuring that all sub-contractors are provided with a copy of the addendum.

Please acknowledge receipt of this information accordingly on page 1 of the Tender Form.

Very truly yours
STRAIT ENGINEERING LIMITED



R. Bruce Latimer, P. Eng.

attch:

WELL # 7 BUILDING

MUNICIPALITY OF THE COUNTY OF ANTIGONISH

PROJECT NO. 18-01

ADDENDUM No. 3

1. Drop pipe for well to be 50mm diameter and to be supplied by the Contractor.
2. Pump intake to be set at 61 m beneath top of well casing.
3. Pitless adapter to be sized for a 75 mm waterline to the building.